

STORMWATER MANAGEMENT

410-887-3768

September 3, 2019

Hazen and Sawyer
1 South Street, Suite 1150
Baltimore, MD 21202
Attn: Julie T. Berry, P.E.

RE: Delmar Sewershed Sanitary Sewer Rehabilitation
Stormwater Management Variance
Back River and Baltimore Harbor Watersheds
EPS Project I.D. M180185
EPS Tracking Number: 07-19-3068

Dear Ms. Berry:

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the rehabilitation of a sanitary sewer by trenchless pipe lining and by cut and cover. The existing cover conditions will be reestablished once the rehabilitation is complete. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Michael P. Doyle of my staff at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Kritty Udhin, P.E., Manager
Stormwater Management
Department of Environmental Protection
& Sustainability

KU:jcm

c: Michael P. Doyle